DNV·GL

Certificate No: TAE00001WX

TYPE APPROVAL CERTIFICATE

This is to certify: That the UPS Eaton 9PX

with type designation(s) 9PX1500IRTM with Marine Filter Unit Type 9PXMF3KI 9PX3000IRTM with Marine Filter Unit Type 9PXMF3KI

Issued to

Eaton Industries France Lianzheng Eelctronic (Shenzhen) Co., Ltd Shenzhen, China

is found to comply with DNV GL rules for classification – Ships, offshore units, and high speed and light craft

Application :

Product(s) approved by this certificate is/are accepted for installation on all vessels classed by DNV GL.

Issued at Hamburg on 2017-05-16

This Certificate is valid until **2022-05-15**. DNV GL local station: **China South NB**

Approval Engineer: Andreas Andrecht

Duy Nam Le Head of Section

for DNV GL

Page 1 of 4

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid. The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.

Job Id: 262.1-023044-1 Certificate No: TAE00001WX

Product description

UPS Unit Type 9PX1500IRTM with Marine Filter Unit Type 9PXMF3KI

UPS Unit type 9PX3000IRTM with Marine Filter Unit Type 9PXMF3KI

| Technical Specification | 1500VA | | | 3000VA | | | |
|----------------------------------|---|----------------------------|--------------------------|-------------------------|-----------------------------|------------------------------|--|
| Rating(VA/W) | 1500VA/1500W | | | 3000VA/3000W | | | |
| Format | RT2U (tower/rack 2U) | | | RT3U (tower/rack 3U) | | | |
| Electrical characteristics | <u>.</u> | | | | | | |
| Nominal voltage | 200/208/220/230/240V | | | | | | |
| Input voltage range | 176-276V without derating (up to 100-276V with derating) | | | | | | |
| Input frequency range | 40-70Hz, 50/60Hz auto selection, frequency converter mode | | | | | | |
| Efficiency | Up to 91% in | 9 | Up to 94% in online mode | | | | |
| Connections | | | | | | | |
| Input | C14 | | | C20 | | | |
| Outputs | C13(8) | | | C13(8), C19(2) | | | |
| Switched outlet group | 2 output groups | | | | | | |
| Batteries | | | | | | | |
| Battery voltage | 48V | | | 72V | | | |
| Battery capacity | 9Ah max | | | | | | |
| Battery backup Time (minutes) | 9PX1500IRTM UPS UPS+1EBM UPS+2EBM | 338W 29,4 115 374 | 42 | 2,2 2,2 1,6 21 | 1013W 7,7 32,1 126 | 1350W 5,5 24,6 89,8 | |
| Battery backup Time (minutes) | 9PX3000IRTM UPS UPS+1EBM UPS+4EBM | 675W 26,5 102 344 | 13 9 4 | 50W 9,1 5,0 65 | 2025W 5,0 29,0 102 | 2700W 3,5 18,5 69,0 | |
| Communication | | | • | | | | |
| Communication ports | 1 USB port / 1 RS232 /1 mini-terminal block for remote On/Off 1 mini-terminal block for remote power off 1 mini-terminal block for output relay | | | | | | |
| Communication Slot | 1 slot for Network-MS card, ModBus-MS or relay-MS card | | | | | | |

Location classes

| Temperature Class | Α |
|-------------------|------|
| Humidity Class | Α |
| Vibration Class | Α |
| EMC Class | В |
| Enclosure | IP20 |

Job Id: 262.1-023044-1 Certificate No: TAE00001WX

Application/Limitation

Operation for longer periods in 40-55°C ambient requires de-rating of the products nominal load to 60%. End user is responsible for correct enclosure protection (IP) with respect to location. This type approval does not replace the requirement for a product certificates in accordance with the DNVGL Rule paragraph Pt.4, Ch.8, Sec. 1, item 2.3 equipment certification To be installed in climatically controlled areas.

Type Approval documentation

Technical info/drawings: Electrical data sheet semiconductor assemblies.docx.pdf Electrical assembly layout.docx.pdf Electrical data sheet general.docx.pdf Electrical assembly functional description.docx.pdf DPD-9PX0-3K1301 Antares_9PX_HV_Technical_specification_V13_2016_3_4.doc Antares 9PX Test Plan OPEX-TE-0001 Antares DNV testing Procedure_20160713.pdf

Test reports: Nemko AS TEST REPORT 323256 EN (IEC 60945:2001 for the Compass Safe Distance requirements) CTI test report EED32I00323001 CTI test report EED32I00322901 CTI test report A2170005964101001 CTI test report A2170005964101002 CTI test report A216000438510102 CTI test report A216000438510101 Sound Power Level Test report DH1_17_0020 Environmental test specification for instrumentation and automation equipment

Tests carried out

Type tests in accordance with tpae approval class programme DNVGL-CP0395. Visual inspection; Electrical Power Supply Failure Test CG 0339 Sec.3 [4]; Power supply Variation Test CG 0339 Sec.3 [5]; Vibration test IEC 60068-2-6 Class A; Dry Heat Test IEC publication 60068-2-2 Class A; Damp heat test IEC publication 60068-2-78 Class A; Temperature rise IEC 60146-1-1 Sec.7.4.2; Functional test (switching of load) IEC 62040-3 Sec.6.2.3; Short time overload IEC 62040-3 Sec.6.7.7...; Short circuit capability IEC 62040-3 Sec.6.7.8; Checking of electrical circuits IEC 62040-3 Sec.6.2.4; Checking of electrical circuits IEC 62040-3 Sec.6.2.4; EMC immunity IEC 62040-2 Sec.3 & CG 0339 Sec.3 [14] Calss B; EMC emission CISPR 16-2-1, 16-2-3; Compass safe distance CG 0339 Sec.3 [15.1]; Acoustic noise and alarm signal levels for equipment installed on the bridge CG 0339 Sec.3 [15.2]

Job Id: 262.1-023044-1 Certificate No: TAE00001WX

Manufacturer

Lianzheng Electronics(Shenzhen) Co., Ltd. No. 4,Liufang Road,67 Block,Xin'an street Office Baoan District,Shenzhen,Guangdong Province,China

Periodical assessment

The scope of the periodical assessment is to verify that the conditions stipulated for the Type approval are complied with and that no alterations are made to the product design or choice of materials.

The main elements of the assessment are:

- Inspection on factory samples, selected at random from the production line (where practicable)
- Results from Routine Tests (RT) checked (if not available tests according to RT to be carried out)
- Review of type approval documentation
- Review of possible change in design, materials and performance
- Ensuring traceability between manufacturer's product type marking and Type Approval Certificate.

Periodical assessment is to be performed after 2 years and after 3.5 years. A renewal assessment will be performed at renewal of the certificate.

END OF CERTIFICATE